



# TATTVA ANALYTICAL LABORATORIES LLP

No:118, Plot No: N1, ITI Industrial Estate, Whitefield Road

Mahadevpur, Bangalore – 560048

Telephone: 9448613741/9886628620

Email: info.tattvalabs@gmail.com, Website: www.tattvalaboratories.com



TAL/FR/MR/31/00

## TEST REPORT

ULR – TC165542600002917F

|                                                                                                                     |                   |                            |                    |
|---------------------------------------------------------------------------------------------------------------------|-------------------|----------------------------|--------------------|
| Name of the Organization:                                                                                           |                   | Date of Sampling           | 27.07.2026         |
| <b>M/S. Divine Providence School</b><br>Chandapura - Dommasandra Rd, P.O,<br>Harohalli, Huskur, Bengaluru – 560099. |                   | Date of Receipt            | 27.07.2026         |
|                                                                                                                     |                   | Date of Analysis started   | 27.07.2026         |
|                                                                                                                     |                   | Date of Analysis Completed | 30.07.2026         |
|                                                                                                                     |                   | Date of Report             | 31.07.2026         |
|                                                                                                                     |                   | Sample drawn by            | Lab Representative |
|                                                                                                                     |                   | Source of collection       | Tap                |
| Sample Code                                                                                                         | TAL/2026/S – 2917 | Sampling container         | Polythene bottle   |
| Nature of Sample                                                                                                    | Water             | Environmental condition    | Normal             |
| Sample Description                                                                                                  | Drinking Water    | Sampling method            | IS:17614           |
| Sample condition when received                                                                                      | Ok                | Sampling Quantity          | 1.0 Ltr            |

### RESULTS

| Sl. No                            | Parameters                          | Units      | Protocol                               | Results        | Standards IS: 10500:2012 |                    |
|-----------------------------------|-------------------------------------|------------|----------------------------------------|----------------|--------------------------|--------------------|
|                                   |                                     |            |                                        |                | Acceptable Limits        | Permissible Limits |
| 1                                 | pH value @ 25°C                     | -          | IS:3025 PART 11: 2022                  | 6.74           | 6.5 to 8.5               | No Relaxation      |
| 2                                 | Odour                               | -          | IS:3025 PART 06: 2018                  | Agreeable      | Agreeable                | Agreeable          |
| 3                                 | Turbidity                           | NTU        | IS:3025 PART 10: 2023                  | 0.1            | 1                        | 5                  |
| 4                                 | Total dissolved solids              | mg/l       | IS:3025 PART 16: 2023                  | 98.0           | 500                      | 2000               |
| 5                                 | Total Hardness as CaCO <sub>3</sub> | mg/l       | IS:3025 PART 21: 2009                  | 48.7           | 200                      | 600                |
| 6                                 | Calcium as Ca                       | mg/l       | IS:3025 PART 40: 2024, Method A        | 15.3           | 75                       | 200                |
| 7                                 | Magnesium as mg                     | mg/l       | IS:3025 PART 46: 2023, Method A        | 2.5            | 30                       | 100                |
| 8                                 | Alkalinity as CaCO <sub>3</sub>     | mg/l       | IS:3025 PART 23: 2023                  | 51.9           | 200                      | 600                |
| 9                                 | Chlorides as Cl                     | mg/l       | IS:3025 PART 32: 1984, Clause2         | 31.7           | 250                      | 1000               |
| 10                                | Sulphates as SO <sub>4</sub>        | mg/l       | IS:3025 PART 24: 2022Sec:1,Clause5     | 8.4            | 200                      | 400                |
| 11                                | Iron as Fe                          | mg/l       | IS:3025 PART 53: 2024, Method A        | BDL (DL - 0.1) | 0.3                      | No Relaxation      |
| 12                                | Fluorides as F                      | mg/l       | IS:3025 PART 60: 2008, Method A        | 0.1            | 1.0                      | 1.5                |
| 13                                | Nitrates as NO <sub>3</sub>         | mg/l       | IS:3025 PART 34: 1988,Clause3,Method B | 2.8            | 45                       | No Relaxation      |
| 14                                | Boron as B                          | mg/l       | IS:3025 PART 57: 2021, Method A        | BDL (DL - 0.1) | 0.5                      | 1.0                |
| <b>Microbiological Parameters</b> |                                     |            |                                        |                |                          |                    |
| 15                                | E. coli                             | Cfu/ 100ml | IS:15185 - 2016                        | <1             | SND                      | SND                |
| 16                                | Total Coliforms Count               | Cfu/ 100ml | IS:15185 - 2016                        | <1             | SND                      | SND                |

Note: SND – Shall not be detectable, BDL- below Detection Limit, DL -Detection Limit, <1 – Indicates not detected, NA – Not Applicable.

*Sangeetha*

AUTHORISED SIGNATORY  
Sangeetha Sathayn GS  
Senior Microbiologist



End of the report.

*Kedar Nath J*

AUTHORISED SIGNATORY  
Kedar Nath J  
Quality Manager

### Note:

- 1) The results listed refer only to the tested samples and applicable parameters. Endorsement of products is neither inferred nor implied.
- 2) The liabilities are restricted to the invoice amount only.
- 3) Microbiological sample will be disposed after 7 days from the analysis completion date, Chemical sample will be disposed after 10 days from the analysis completion date, unless otherwise specified. Gaseous samples will be discarded after analysis.
- 4) This report is not to be reproduced wholly or in part, and cannot be used as evidence in a court of law or as any advertisement media without special permission in writing.